

Message

From: Moore, Kendall [moore.kendall@epa.gov]
Sent: 4/26/2017 2:43:55 PM
To: piplicd@monroe.wednet.edu; Deka Smith [smithf@monroe.wednet.edu]; John Mannix [mannixj@monroe.wednet.edu]; Amanda Zych [azych@snohd.org]; Kevin Plemel [kplemel@snohd.org]
CC: Ramanauskas, Peter [ramanauskas.peter@epa.gov]; Mullin, Michelle [Mullin.Michelle@epa.gov]; Peachey, Robert [peachey.robert@epa.gov]
Subject: Fw: RESENDING FINAL RESULTS- Sky Valley Education Center OCE-009D PCB (Complete)
Attachments: Sky Valley OCE-009D PCB.pdf

Here are the results from my sampling in the electrical rooms of SVEC on April 11, 2017. All the results are below TSCA action levels and during my inspection there was no indication that PCB containing equipment was in use in those spaces. Please share with anyone that I left off of this distribution list.
